

FIRE UNDERWRITERS SURVEY A SERVICE TO INSURERS AND MUNICIPALITIES

c/o Opta Information Intelligence

May 16th, 2017

RECOGNITION FOR FIRE INSURANCE GRADING RECEIVED

Sturgeon County
Sturgeon County Protective Services – Namao Fire Station

Superior Tanker Shuttle Service - Accredited

I am pleased to advise you that the above mentioned fire protection area was recently registered in the Fire Insurance Grading Index as being accredited for the delivery of Superior Tanker Shuttle Service.

The requirements for this accreditation are stringent and verify that the fire protection district is capable of delivering the minimum <u>accepted</u> fire flows to detached dwellings throughout the fire protection district within 8 kilometres by road of the responding fire station and 5km by road of a water supply point. This accreditation is an equivalency to the minimum requirements for hydrant protection as set out by the insurance industry and the Fire Underwriters Survey. Dwelling Protection Grade 3B(S) should be applied to properties insured under Personal Lines that are within 8km road distance from the accredited fire hall and 5km road distance of a water supply point as outlined in the Fire Insurance Grade map for the District.

Fire Underwriters Survey has provided information on fire protection and risk levels to the insurance industry in Canada for more than 100 years. Fire Underwriters Survey was originally operated under the auspices of the Insurance Advisory Organization until 2002 when the I.A.O. and all of its related services were repositioned under the flag of CGI and more recently, Opta Information Intelligence.

Should you have any questions or concerns related to the Fire Underwriters Survey, the Superior Shuttle Accreditation process or any other related area, please contact our office.

Robert McGuinness, P.Eng, PMSFPE, Public Fire Protection Specialist, Fire Underwriters Survey.